

**Roanoke Regional Airport Commission
IFB #22-007
Camfil CitiCarb I Absorber Type Cartridge Filters**

**Addendum #1
July 8, 2022**

The contents of this addendum represent solicitation questions and answers, notes, changes, additions or clarifications to the specifications.

Questions and Answers – RRAC IFB #22-007 – Camfil CitiCarb I Absorber Type Cartridge Filters

- Q1. Can you confirm you are looking for 24x24x12 single header models and can your team consider a direct purchase to expedite the product arrival?
- A1. Per page PC-1, Section 1.3 of the IFB, RRAC is looking for 24"W x 24"H x 12"D single header model cartridge filters. RRAC cannot consider a direct purchase due to public procurement competition requirements.
- Q2. Can an equivalent brand be used in place of the name brand – Camfil – CityCarb I for the Qty 37 filters for this Invitation for Bid?
- A2. An equivalent brand may be used in place of the name brand Camfil. Any article which RRAC, in its sole discretion, determines to be the equivalent of that specified, considering quality, workmanship, economy of operation and suitability for the purpose intended, shall be accepted. If an equivalent item is bid, it is the bidder's responsibility to provide sufficient detailed product specifications for the equivalent item with their bid for RRAC to review to make an equivalency determination when evaluating the bid.